




SERIES-2000


ARCHITECTURAL ROOFING



Seam w/clip before seaming



Seam w/clip after seaming



Double locked seam w/clip

SPECIFICATIONS

PART I GENERAL

SUMMARY

- B. Section includes: all material, labor, and equipment to complete installation of Amp Lok as shown on the drawings and herein specified. Include all copings, gutters, and flashings contiguous with the panels.
- C. Related Sections
 1. Metal decking
 2. Rough carpentry, plywood, and underlayment
 3. Insulation
 4. Membrane roofing
 5. Flashing and sheet metal
 6. Joint sealers: sealants and caulk
 7. Structural framing.

SYSTEM DESCRIPTION

- A. Performance Requirements: Provide factory formed, prefinished, mechanically seamed, concealed clip, structural standing seam metal roof system, that has been pretested and certified by manufacturer to comply with specified requirements under installed conditions.
 1. Provide UL90 rated roofing system that has been tested in accordance with UL 580 test procedure.
 2. Resistance to air leakage: 0.01 cfm/ft. of joint leakage when tested in accordance with ASTM E 283 at static pressure differential of 15 psf.
 3. Resistance to water penetration: No leakage through panel joints when tested in accordance with ASTM E 331 at static pressure differential of 6.24 psf.
- B. Structural Requirements: Engineer panels for structural properties in accordance with latest edition of American Iron and Steel Institute *Cold Formed Steel Design Manual*, using "effective width" concept.
- C. Maximum clip spacing shall be 4' o.c.

SUBMITTALS

- A. Product Data: submit manufacturer's specifications, standard profile sheet, product data brochure and finish warranty.
- B. Shop Drawings: shop drawings showing roof plan with layout of panels, clips, clip attachment, underlayment and sections of each flashing/trim condition shall be submitted for approval prior to fabrication. Drawings shall contain material type, metal thickness and finish. Drawings shall distinguish between factory and field fabrication.
- C. Samples:
 1. Submit sample 12" long x full width panel, showing proposed metal gauge, seam profile and specified finish.
 2. Submit manufacturer's standard colors for Architect's selection.

QUALITY ASSURANCE

- A. Panel manufacturer shall have a minimum of ten (10) years of experience in manufacturing architectural roofing in a permanent stationary indoor facility.
- B. Panel installer shall have a minimum of two (2) years experience in the installation of concealed clip architectural standing seam metal roofing and show evidence of successful completion of at least three (3) projects of similar size, scope, and complexity.

DELIVERY, STORAGE, and HANDLING

- A. Panels and flashings shall be protected and properly packaged to protect against transportation damage in transit to the jobsite.
- B. Upon delivery, exercise care in unloading, stacking, moving, storing, and erecting panels and flashings to prevent twisting, bending, scratching, or denting.
- C. Store panels and flashings in a safe, dry environment under a waterproof covering to prevent water damage. Allow for adequate ventilation to prevent condensation. Panels and flashings with strippable film shall not be stored in direct sunlight.
- D. Upon installation immediately remove strippable film from panels and flashings. Protect panels and flashings from foot traffic and from all other trades.

PROJECT CONDITIONS

- A. Field dimensions shall be taken prior to fabrication to verify jobsite conditions.
- B. Minimum recommended pitch for this panel is 1/2":12.
- C. Maximum panel length is 55' (contact the factory for longer panels).

WARRANTIES

- A. Panel manufacturer shall provide a forty (40) year warranty on the paint finish covering chalking, cracking, checking, chipping, blistering, peeling, and flaking.
- B. Applicator shall furnish written warranty for a two (2) year period from date of substantial completion of building covering repairs required to maintain roof and flashings in watertight conditions.

PART II PRODUCTS

PRODUCT DESCRIPTION

- A. NRM-2000 structural standing seam roof system as manufactured by Nu-Ray Metals, 1234 37th street NW Auburn, WA, ph.: 800-700-7228; fax: 888-797-5618
- B. The NRM-2000 panel shall have a coverage of 12", 16", or 20". Seams shall be 1-1/2" high.
- C. Roof panels shall use a combination of one-piece and two-piece roof clips allowing for thermal movement of the panel system.
- D. The panel shall be mechanically seamed with a field operated electric seaming machine provided by the manufacturer.
- E. The panel system shall be as a true standing seam shape requiring no trapezoidal foam closures, plugs, or fillers at eaves.

F. Field applied sealant to joints is necessary on roof pitches under 3:12.

PRODUCT SUBSTITUTIONS

- A. Requests to use alternate systems shall be submitted in writing to the project designer at least ten (10) days prior to bid date. Request shall demonstrate proposed substitution meets or exceeds specified performance requirements. Certified statements, samples and descriptive data shall be included in this submittal request.

B. Manufacturers listed in this section are prequalified manufacturers. Substitution of manufacturer's products for those specified shall not be allowed at any time during construction.

SPECIFICATIONS (continued)

MATERIALS AND FINISHES

- A. Panel materials
- 24 gauge, Grade 50 (50 ksi yield strength) structural steel with G90 (0.90 oz./ft.²) hot dipped galvanized coating, both conforming to ASTM A 653.
 - 24 gauge, Grade 50 (50 ksi yield strength) structural steel with AZ50 (0.50 oz./ft.²) aluminum-zinc alloy coating, both conforming ASTM A 792.
- B. Texture: steel shall be smooth.
- C. Finish: Finish: paint shall be full strength 70% polyvinylidene fluoride Kynar 500 Ultra COOL® fluorocarbon baked-on coating, factory applied prior to roll forming. The treatment shall be a two-coat system consisting of a single coat of 0.2 mil primer followed by a finish coat of 0.8 mil Kynar topcoat with a total dry film thickness of 1.0 mil ± 0.2 mil. The reverse side of the panels shall be treated with a back coat system consisting of a 0.2 mil primer with a 0.3 mil topcoat for a total dry film thickness 0.5 mil.

ACCESSORIES

- A. Concealed roof clips:
- 2 pc.: 24 ga. sliding
 - 1 pc.: 24 ga. fixed clip (for use with short panel lengths only).
- B. Flashing and Trim
- All flashing and trim shall be of the same material, gauge, finish, and color as the roof panels and fabricated in accordance with standard SMACNA procedure and details.
 - Provide transition rib covers where roofing changes pitch.
 - Fabricate gutters and downspouts in the same gauge, material, finish, and color as the roof panels.
- C. Fasteners
- Clips to substrate: Screw shall be #12 or #14 diameter, self tapping type, zinc-plated steel.
 - Flashings to panels: exposed screws shall be zinc plated with a #14 x 7/8" combination steel and neoprene washer, color to match panel.
 - Pop rivets: #43 stainless steel, color finish to match panel.
- D. Sealants
- Shall not contain oil, asbestos, or asphalt.
 - Factory applied sealant shall be applied in the seam and designed for metal to metal concealed joints.
 - Field applied panel end sealant shall be mastic tape sealant.
 - Exposed sealant shall be one-part polyurethane joint sealant. Coordinate color with roof panels.
- E. Closures
- Ridge and hip closures shall be protected and supported by a formed metal closure manufactured from the same material, color, and finish as the panels.
 - Metal closures shall be factory-fabricated and field-cut as needed.

RELATED MATERIALS

- A. Refer to other sections listed in Related Sections paragraph for related materials.

FABRICATION

- A. Roof panels shall be formed in continuous lengths.
- B. Panels shall be roll formed on a stationary industrial type rolling mill to gradually shape the sheet metal or specified manufactures portable rollformer for lengths over 55'. Portable rollformers, rented or owned by the installer, are not acceptable.
- C. Fabricate flashings from the same material as the roof system.

SOURCE QUALITY

- A. Source Quality: obtain metal panels and accessories from a single manufacturer.

- B. Fabrication tolerances: follow tolerances in MCA's Preformed Metal Wall Guidelines.
- C. Tests and inspections
- D. Verification of performance

PART III EXECUTION

MANUFACTURER'S INSTRUCTIONS

- A. Compliance: Comply with manufacturer's product data, including product technical bulletins, product catalog installation instructions, and product cartons for installation.

EXAMINATION

- B. Installer shall:
- Inspect roof purlins and/or roof deck to verify that it complies with shop drawings and is smooth, even, sound, and free of depressions.
 - Report variations and potential problems in writing to the architect.

INSTALLATION

- A. Conform to the standard set forth in the SMACNA architectural sheet metal manuals and the approved shop drawings detailed for the project.
- B. Install panels plumb, level, and straight with the seams parallel, conforming to the design as indicated.
- C. Install panel system so it is watertight, without waves, warps, buckles or distortions, and allow for thermal movement considerations.
- D. Abrasive devices shall not be used to cut on or near roof panel system.
- E. Apply sealant tape or caulking as necessary at flashing and panel joints to prevent water penetration.
- F. Remove any strippable film immediately upon exposure to direct sunlight.
- G. Hand-crimp seams at each clip or mechanically seam before workers stand on panels.
- H. Seam panels together with electric-powered seaming machine supplied by the panel manufacturer for a weathertight seam.
- I. Vapor retarder: The joints, perimeter, and all openings shall be sealed per the manufacturer's instructions to provide a continuous vapor retarder.
- J. Underlayment (solid substrate):
- Provide one layer of 30# felt with horizontal overlaps and endlaps staggered between layers.
 - Provide ice and water shield membrane at all valley and eave conditions as well as any area at less than a 3:12 slope.
 - Lay parallel to ridge line with 2 1/2" horizontal laps and 6" vertical laps.

CLEANING

- A. Dispose of excess materials and debris from jobsite.
- B. Remove filings, grease, stains, marks, or excess sealants from roof panel system to prevent staining.
- C. Protect work from damage from other trades until final acceptance.

Kynar® 500 is a registered trademark of Atofina Chemicals.